



- AC UNIT
WILL BE SHIPPED
LOOSE
- MAYBE CONNECTION
BOXES SHIPPED LOOSE

ADD
- LT SWITCHES
- INT & EXT RECEPTACLES

ADD GROUND BAR
& GRD TO EXTERNAL
GROUNDS
INSTALL IN BOX
UNDER PLC CABINET

no!
INSTALL CHASE
14/13/12

AEA ARIZONA ELECTRICAL APPARATUS TUCSON, AZ	PROJECT: WATER SYSTEM BOOSTER PUMP E-HOUSE
	DWG TITLE: E-HOUSE PLAN VIEWS
	DWG NO. AEA-110112-09
	DATE: 11/01/12 ORIGIN: JB SHEET NO. 9 OF 17 REV P2

CLIENT REVIEW _____
DATE _____
AS BUILT: 000000